Comprehensive Certification Systems

1) Quality Management System Certification ISO9001:2008



The Authentication Certificate
Of Quality Management System

Jiangsu Wetown Busway Co., Ltd.

Address: No.1 Nanzi Road, Technology Park Xinba Town, Yangzhong, Jiangsu P R.China P.C.: 212212

According to your organization's application, our center carried out audit and certification in accordance with the requirements for *Quality Management System* (GB/T19001-2008 idt ISO9001:2008), through the assessment, it is in accordance with the requirements which set up the quality management system.

The scope of the certified QMS is:

Design, R&D, production, service of High Voltage Busduct, Insulated Pipe Busduct, Gas Insulated Line Busduct, and Low Voltage Busway.

Registration No. of Certificate:	05311Q10001R4M-6
Date of the Awarded Certificate:	2-4-2011
Term of the Certificate's Validity:	2-4-2011~1-4-2014
Date of the First Authentication:	8-4-2005

If not stick the laser surveillance mark after the date of surveillance expires, this certificate is invalid.

The first surveillance	Mark stick here	The second surveillance	Mark stick here

MANAGEMENT SYSTEM
CNAS C053-Q

Beijing NGV Certification Center Director: Zengjian

Address of Certification Authority: F/18, Building C, Focus Square, Futong East Street, Chaoyang District, Beijing.
Tel: 010-84785070 P.C.: 100102 Http://www.ngv.org.cn

2) Environmental Management System Certification ISO14001:2004



The Authentication Certificate
Of Environmental Management System

Jiangsu Wetown Busway Co., Ltd.

Address: No.1 Nanzi Road, Technology Park Xinba Town, Yangzhong, Jiangsu P R.China P.C.: 212212

According to your organization's application, our center carried out audit and certification in accordance with the requirements with guidance for use of *Environmental Management System* (GB/T24001-2004/ISO14001:2004), through the assessment, it is in accordance with the requirements which set up the environmental management system.

The scope of the certified EMS is:

The environmental management, by Jiangsu Wetown Busway Co., Ltd. with location at No. 1 Nanzi Road, Xinba Technology park, Yangzhong city, Jiangsu province, in the process of design, R&D, production, after-sales service for High Voltage Busduct, Insulated Pipe Busduct, Gas Insulated Line Busduct, and Low Voltage Busway.

Registration No. of Certificate:	05311E20004R2M-6
Date of the Awarded Certificate:	2-4-2011
Term of the Certificate's Validity:	2-4-2011~1-4-2014
Date of the First Authentication:	10-5-2005

If not stick the laser surveillance mark after the date of surveillance expires, this certificate is invalid.

The first surveillance	Mark stick here	The second surveillance	Mark stick here

MANAGEMENT SYSTEM
CNAS C053-E

Beijing NGV Certification Center Director: Zengjian

Address of Certification Authority: F/18, Building C, Focus Square, Futong East Street, Chaoyang District, Beijing.

Tel: 010-84785070 P.C.: 100102 Http://www.ngv.org.cn

3) Occupational Health Management System Certification T28001-2001



The Authentication Certificate
Of Occupational Health and Safety
Management System

Jiangsu Wetown Busway Co., Ltd.

Address: No.1 Nanzi Road, Technology Park Xinba Town, Yangzhong, Jiangsu P R.China P.C.: 212212

According to your organization's application, our center carried out audit and certification in accordance with the specification for *Occupational Health and Safety Management System* (GB/T28001-2001), through the assessment, it is in accordance with the requirements which set up the occupational health and safety management system.

The scope of the certified OHSMS is:

The occupational health & safety management, by Jiangsu Wetown Busway Co., Ltd. with location at No. 1 Nanzi Road, Xinba Technology park, Yangzhong city, Jiangsu province, in the process of design, R&D, production, after-sales service for High Voltage Busduct, Insulated Pipe Busduct, Gas Insulated Line Busduct, and Low Voltage Busway.

Registration No. of Certificate:	05311S10008R1M-6
Date of the Awarded Certificate:	2-4-2011
Term of the Certificate's Validity:	2-4-2011~1-4-2014
Date of the First Authentication:	7-4-2008

If not stick the laser surveillance mark after the date of surveillance expires, this certificate is invalid.

The first surveillance	Mark stick here	The second surveillance	Mark stick here

CNAS

MANAGEMENT SYSTEM
CNAS C053-S

Beijing NGV Certification Center Director: Zengjian

Address of Certification Authority: F/18, Building C, Focus Square, Futong East Street, Chaoyang District, Beijing.
Tel: 010-84785070 P.C.: 100102 Http://www.ngv.org.cn

4) Social Responsibility System Certification SA 8000:2008



BUREAU VERITAS
Certification

BUREAU VERITAS 1828

Certification
Awarded to

JIANGSU WETOWN BUSWAY CO., LTD.

NO.1 NANZI ROAD, TECHNOLOGY PARK, XINBA TOWN, YANGZHONG CITY, JIANGSU, CHINA

Bureau Veritas Certification certify that the Management System of the above organisation has been audited and found to be in accordance with the requirements of the management system standards detailed below

STANDARD

SA 8000:2008

SCOPE OF SUPPLY

DESIGN, DEVELOPMENT, MANUFACTURING AND SALES OF HIGH VOLTAGE BUS AND LOW VOLTAGE BUSWAY

Original Approval Date : 08 FEBRUARY 2010
Subject to the continued satisfactory operation of the organisation's Management System, this ***certificate is*** *valid until:* **:**
07 FEBRUARY 2013

To check the validity of this certificate please call (0086 21 68860643)
Further clarification regarding the scope of this certificate and the applicability of the management system requirements may be obtained by consulting the organisation

Date: : 08 FEBRUARY 2010

Certificate Number : IND109548

Managing Office:
8/F Building No.8 Pudong Lujiazui Software Park, No.120, Lane 91, E Shan Road, Pudong, Shanghai, China. 200120

Certification Authority Office:
ICC SA 8000 Italy
Via Di Corticella, 181/3, 40128 Bologna, Italy

5) Service System Certification T10401-2006



Certificate No:
CAS20111201 R2M-5(4-5)

★★★★★

Certificate for Service System Certification

This is to certify that

Jiangsu Wetown Busway Co., Ltd

No.1,Nanzi Road,Technology Park,Xinba Town,Yangzhong City,Jiangsu Province
Post code:212200

Operates a service system which has been assessed as conforming to

CHINA SB/T10401-2006

FIVE STAR

For the scope of activities

LV/LZ serial compact busway,LM serial compact busway, LB serial lighting busway LB1 serial small current busway LH serial middle current busway LM-N serial fire resistant busway HM serial compact busway LK serial air-insulated busway GM serial cast resin busway Q(B)JGM serial insulation pipe busduct QLFM serial insulated phase busduct, GGM serial seperated non-segerated phase busduct GLM serial cable insulation busduct GFM serial non-segerated phase busduct WLK/WLH serial wind power busway

Certified since: 06 December 2011

This certificate is valid from 06 December 2011 **until** 05 December 2014

The effectiveness of this certificate shall be validated by periodic surveillance audit of BSCC for maintenance;
Conditions on effectiveness of certificate see http://www.bscc.org.cn

National Commodity After-sales Service Conformity Certification Evaluation Committee

Beijing Sky Certification Center

ISSUED BY

Add: 404, NO.1 Building, 45 NeiDa Street,FuXingMen,BeiJing,P.R.China Tel:+86(10)66094341

Certificate and Test Report

KEMA Test Certificate

LV400A、630A KEMA Test Certificate

TEST CERTIFICATE

Issued to:	Jiangsu Wetown Busway Co., Ltd. No. 1 Nanzi Road, Technology Park Xinba Town, Yangzhong, Jiangsu P. R. China
For the product:	Low-voltage busbar trunking system (copper bar) with/without tap off unit outlet
Trade name:	Wetown
Type/Model:	LV-400 A, LV-630 A
Ratings:	In: LV-400 A: 400 A, 50 Hz LV-630 A: 630 A, 50 Hz Ue: 690 V Icw: 3-phase 30 kA – 1,0 s with a peak of 63 kA Neutral 18 kA – 1,0 s with a peak of 36 kA PE 18 kA – 0,5 s with a peak of 36 kA
Manufactured by:	Jiangsu Wetown Busway Co., Ltd. No. 1 Nanzi Road, Technology Park Xinba Town, Yangzhong, Jiangsu P. R. China
Subject:	Type tests
Requirements:	IEC 60439-2, 3rd ed. 2000-03 and Amendment A1 2005-08 Clauses: 8.2.1, 8.2.2, 8.2.3, 8.2.4, 8.2.5, 8.2.7, 8.2.9, 8.2.10, 8.2.12 and 8.2.13
Remarks:	Not applicable

This Test Certificate is granted on account of an examination by DEKRA, the results of which are laid down in report no. 3301649.01, dated January 24, 2011.

The examination has been carried out on one single specimen of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA

nhem, January 24, 2011

Number: 3301649.100

DEKRA Certification B.V.

H.L. Schendstok
Certification Manager

© Integral publicatio rtificate and adjoining reports is allowed

All testing, inspection, d certification activities of the former KEMA Quality are an integral part of the DEKRA Certification Group.

DEKRA Certification B.V. U g 310, 6812 AR Arnhem P.O. Box 5185, 6802 ED Arnhem, The Netherlands
T +31 26 356 2000 F +31 26 www.dekra-certification.com Company registration 09085396

LV800A KEMA Test Certificate

KEMA Quality

TEST CERTIFICATE

No. 3301287.101

Issued to:	Jiangsu Wetown Busway Co., Ltd. No.1, Nanzi Road, Technology Park, Xinba Town, Yangzhong City Jiangsu, China
For the product:	low-voltage busbar trunking system (copper bar)
Trade name:	Wetown
Type/Model:	LV-800 A
Ratings:	In: 800 A, Ue: 690 V
Manufactured by:	Jiangsu Wetown Busway Co., Ltd. No.1, Nanzi Road, Technology Park, Xinba Town, Yangzhong City Jiangsu, China
Subject:	Partial type tests
Requirements:	IEC 60439-2, 3rd ed. 2000-03 and Amendment A1 2005-08; Clauses: 8.2.1, 8.2.2, 8.2.4, 8.2.5, 8.2.7, 8.2.9, 8.2.10, 8.2.12 and 8.2.13
Remarks:	-

This Test Certificate is granted on account of an examination by KEMA Quality, the results of which are laid down in report no. 3301287.02, dated August 3, 2010.

The examination has been carried out on one single specimen of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by KEMA Quality is not the responsibility of KEMA Quality

KEMA Quality B.V.
Arnhem, August 3, 2010

H.R.M. Barends
Certification Manager

© Integral publication of this certificate and adjoining reports is allowed

KEMA Quality B.V. Utrechtseweg 310, 6812 AR Arnhem P.O. Box 5185, 6802 ED Arnhem, The Netherlands
T +31 26 356 2000 F +31 26 352 5600 www.kemaquality.com Company registration 09085396

a DEKRA company

LV1000A KEMA Test Certificate

TEST CERTIFICATE

Issued to:	Jiangsu Wetown Busway Co., Ltd. No. 1 Nanzi Road, Technology Park Xinba Town, Yangzhong, Jiangsu P. R. China
For the product:	Low-voltage busbar trunking system (copper bar) with/without tap off unit outlet
Trade name:	Wetown
Type/Model:	LV-1000 A
Ratings:	In: 1000 A, 50 Hz Ue: 690 V Icw: 3-phase 50 kA – 1,0 s with a peak of 105 kA Neutral 30 kA – 1,0 s with a peak of 63 kA PE 30 kA – 0,5 s with a peak of 63 kA
Manufactured by:	Jiangsu Wetown Busway Co., Ltd. No. 1 Nanzi Road, Technology Park Xinba Town, Yangzhong, Jiangsu P. R. China
Subject:	Type tests
Requirements:	IEC 60439-2, 3rd ed. 2000-03 and Amendment A1 2005-08 Clauses: 8.2.1, 8.2.2, 8.2.3, 8.2.4, 8.2.5, 8.2.7, 8.2.9, 8.2.10, 8.2.12 and 8.2.13
Remarks:	Not applicable

This Test Certificate is granted on account of an examination by DEKRA, the results of which are laid down in report no. 3301649.02, dated January 24, 2011.

The examination has been carried out on one single specimen of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA

nhem, January 24, 2011

Number: 3301649.101

DEKRA Certification B.V.

H.L. Schendstok
Certification Manager

© Integral publication ... rtificate and adjoining reports is allowed

All testing, inspection, au... nd certification activities of the former KEMA Quality are an integral part of the DEKRA Certification Group.

DEKRA Certification B.V. Utre... veg 310, 6812 AR Arnhem P.O. Box 5185, 6802 ED Arnhem, The Netherlands
T +31 26 356 2000 F +31 26 3... www.dekra-certification.com Company registration 09065396

LV1250A KEMA Test Certificate



TEST CERTIFICATE

Issued to:	Jiangsu Wetown Busway Co., Ltd. No. 1 Nanzi Road, Technology Park Xinba Town, Yangzhong, Jiangsu P. R. China
For the product:	Low-voltage busbar trunking system (copper bar) with/without tap off unit outlet
Trade name:	Wetown
Type/Model:	LV-1250 A
Ratings:	In: 1250 A, 50 Hz Ue: 690 V Icw: 3-phase 50 kA – 1,0 s with a peak of 105 kA Neutral 30 kA – 1,0 s with a peak of 63 kA PE 30 kA – 0,5 s with a peak of 63 kA
Manufactured by:	Jiangsu Wetown Busway Co., Ltd. No. 1 Nanzi Road, Technology Park Xinba Town, Yangzhong, Jiangsu P. R. China
Subject:	Type tests
Requirements:	IEC 60439-2, 3rd ed. 2000-03 and Amendment A1 2005-08 Clauses: 8.2.1, 8.2.2, 8.2.3, 8.2.4, 8.2.5, 8.2.7, 8.2.9, 8.2.10, 8.2.12 and 8.2.13
Remarks:	Not applicable

Certificate is granted on account of an examination by DEKRA, the results of which are laid down in report no. 3301649.03, dated January 24, 2011.

The examination has been carried out on one single specimen of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA

Arnhem, January 24, 2011

Number: 3301649.102

DEKRA Certification B.V.

H.L. Schendstok
Certification Manager

© Integral publication of this certificate and adjoining reports is allowed

All testing, inspection, and certification activities of the former KEMA Quality are an integral part of the DEKRA Certification Group.

DEKRA Certification B.V. Utrechtseweg 310, 6812 AR Arnhem P.O. Box 5185, 6802 ED Arnhem, The Netherlands
T +31 26 356 2000 F +31 26 3[illegible] www.dekra-certification.com Company registration 09085396

LV1600A KEMA Test Certificate

KEMA Quality

TEST CERTIFICATE

No. 3301287.100

Issued to:	Jiangsu Wetown Busway Co., Ltd. No.1, Nanzi Road, Technology Park, Xinba Town, Yangzhong City Jiangsu, China
For the product:	low-voltage busbar trunking system (copper bar)
Trade name:	Wetown
Type/Model:	LV-1600 A
Ratings:	In: 1600 A, Ue: 690 V, Icw: 65 kA – 1,0 s
Manufactured by:	Jiangsu Wetown Busway Co., Ltd. No.1, Nanzi Road, Technology Park, Xinba Town, Yangzhong City Jiangsu, China
Subject:	Type tests
Requirements:	IEC 60439-2, 3rd ed. 2000-03 and Amendment A1 2005-08; Clauses: 8.2.1, 8.2.2, 8.2.3, 8.2.4, 8.2.5, 8.2.7, 8.2.9, 8.2.10, 8.2.12 and 8.2.13
Remarks:	-

This Test Certificate is granted on account of an examination by KEMA Quality, the results of which are laid down in report no. 3301287.01, dated August 3, 2010.

The examination has been carried out on one single specimen of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by KEMA Quality is not the responsibility of KEMA Quality

KEMA Quality B.V.
Arnhem, August 3, 2010

H.R.M. Barends
Certification Manager

© Integral publication of this certificate and adjoining reports is allowed

KEMA Quality B.V. Utrechtseweg 310, 6812 AR Arnhem P.O. Box 5185, 6802 ED Arnhem, The Netherlands
T +31 26 356 2000 F +31 26 352 5800 www.kemaquality.com Company registration 09085396

a DEKRA company

LV2000A KEMA Test Certificate



TEST CERTIFICATE

Issued to:	Jiangsu Wetown Busway Co , Ltd. No. 1 Nanzi Road, Technology Park Xinba Town, Yangzhong, Jiangsu P. R. China
For the product:	Low-voltage busbar trunking system (copper bar) with/without tap off unit outlet
Trade name:	Wetown
Type/Model:	LV-2000 A
Ratings:	In: 2000 A, 50 Hz Ue: 690 V Icw: 3-phase 65 kA – 1,0 s with a peak of 143 kA Neutral 39 kA – 1,0 s with a peak of 81,9 kA PE 39 kA – 0,5 s with a peak of 81,9 kA
Manufactured by:	Jiangsu Wetown Busway Co., Ltd. No. 1 Nanzi Road, Technology Park Xinba Town, Yangzhong, Jiangsu P. R. China
Subject:	Type tests
Requirements:	IEC 60439-2, 3rd ed. 2000-03 and Amendment A1 2005-08 Clauses: 8.2.1, 8.2.2, 8.2.3, 8.2.4, 8.2.5, 8.2.7, 8.2.9, 8.2.10, 8.2.12 and 8.2.13
Remarks:	Not applicable

This Test Certificate is granted on account of an examination by DEKRA, the results of which are laid down in report no. 3301649.04, dated January 24, 2011.

The examination has been carried out on one single specimen of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA

Arnhem, January 24, 2011 Number: 3301649.103

DEKRA Certification B.V.

H.L. Schendstok
Certification Manager

© Integral publication of this certificate and adjoining reports is allowed

All testing, inspection, and certification activities of the former KEMA Quality are an integral part of the DEKRA Certification Group.

DEKRA Certification B.V. Utrechtseweg 310, 6812 AR Arnhem P.O. Box 5185, 6802 ED Arnhem, The Netherlands
T +31 26 356 2000 F +31 26 [illegible] www.dekra-certification.com Company registration 09085396

LV2500A KEMA Test Certificate

TEST CERTIFICATE

Issued to:	Jiangsu Wetown Busway Co., Ltd. No. 1 Nanzi Road, Technology Park Xinba Town, Yangzhong, Jiangsu P. R. China
For the product:	Low-voltage busbar trunking system (copper bar) with/without tap off unit outlet
Trade name:	Wetown
Type/Model:	LV-2500 A
Ratings:	In: 2500 A, 50 Hz Ue: 690 V Icw: 3-phase 65 kA – 1,0 s with a peak of 143 kA Neutral 39 kA – 1,0 s with a peak of 81,9 kA PE 39 kA – 0,5 s with a peak of 81,9 kA
Manufactured by:	Jiangsu Wetown Busway Co., Ltd. No. 1 Nanzi Road, Technology Park Xinba Town, Yangzhong, Jiangsu P. R. China
Subject:	Type tests
Requirements:	IEC 60439-2, 3rd ed. 2000-03 and Amendment A1 2005-08 Clauses: 8.2.1, 8.2.2, 8.2.3, 8.2.4, 8.2.5, 8.2.7, 8.2.9, 8.2.10, 8.2.12 and 8.2.13
Remarks:	Not applicable

This Test Certificate is granted on account of an examination by DEKRA, the results of which are laid down in report no. 3301649.05, dated January 24, 2011.

The examination has been carried out on one single specimen of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA

rnhem, January 24, 2011 Number: 3301649.104

DEKRA Certification B.V.

H.L. Schendstok
Certification Manager

© Integral publication icate and adjoining reports is allowed

All testing, inspection, au rtification activities of the former KEMA Quality are an integral part of the DEKRA Certification Group.

DEKRA Certification B.V. Utrec 6812 AR Arnhem P.O. Box 5185, 6802 ED Arnhem, The Netherlands
T +31 26 356 2000 F +31 26 352 w ra-certification.com Company registration 09085396

LV3200A KEMA Test Certificate

TEST CERTIFICATE

Issued to:	Jiangsu Wetown Busway Co., Ltd. No. 1 Nanzi Road, Technology Park Xinba Town, Yangzhong, Jiangsu P. R. China
For the product:	Low-voltage busbar trunking system (copper bar) with/without tap off unit outlet
Trade name:	Wetown
Type/Model:	LV-3200 A
Ratings:	In: 3200 A, 50 Hz Ue: 690 V Icw: 3-phase 120 kA – 1,0 s with a peak of 264 kA Neutral 72 kA – 1,0 s with a peak of 158,4 kA PE 72 kA – 0,5 s with a peak of 158,4 kA
Manufactured by:	Jiangsu Wetown Busway Co., Ltd. No. 1 Nanzi Road, Technology Park Xinba Town, Yangzhong, Jiangsu P. R. China
Subject:	Type tests
Requirements:	IEC 60439-2, 3rd ed. 2000-03 and Amendment A1 2005-08 Clauses: 8.2.1, 8.2.2, 8.2.3, 8.2.4, 8.2.5, 8.2.7, 8.2.9, 8.2.10, 8.2.12 and 8.2.13
Remarks:	Not applicable

This Test Certificate is granted on account of an examination by DEKRA, the results of which are laid down in report no. 3301649.06, dated January 24, 2011.

The examination has been carried out on one single specimen of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA

rnhem, January 24, 2011 Number: 3301649.105

DEKRA Certification B.V.

H.L. Schendstok
Certification Manager

© Integral publication rtificate and adjoining reports is allowed

All testing, inspection, au d certification activities of the former KEMA Quality are an integral part of the DEKRA Certification Group.

DEKRA Certification B.V. Utre g 310, 6812 AR Arnhem P.O. Box 5185, 6802 ED Arnhem, The Netherlands
T +31 26 356 2000 F +31 26 35 www.dekra-certification.com Company registration 09085396

LV4000A KEMA Test Certificate

TEST CERTIFICATE

Issued to:	Jiangsu Wetown Busway Co., Ltd. No. 1 Nanzi Road, Technology Park Xinba Town, Yangzhong, Jiangsu P. R. China
For the product:	Low-voltage busbar trunking system (copper bar) without tap off unit outlet
Trade name:	Wetown
Type/Model:	LV-4000 A
Ratings:	In: 4000 A, 50 Hz Ue: 690 V Icw: 3-phase 120 kA – 1,0 s with a peak of 264 kA Neutral 72 kA – 1,0 s with a peak of 158,4 kA PE 72 kA – 0,5 s with a peak of 158,4 kA
Manufactured by:	Jiangsu Wetown Busway Co., Ltd. No. 1 Nanzi Road, Technology Park Xinba Town, Yangzhong, Jiangsu P. R. China
Subject:	Type tests
Requirements:	IEC 60439-2, 3rd ed. 2000-03 and Amendment A1 2005-08 Clauses: 8.2.1, 8.2.2, 8.2.3, 8.2.4, 8.2.5, 8.2.7, 8.2.9, 8.2.10, 8.2.12 and 8.2.13
Remarks:	Not applicable

This Test Certificate is granted on account of an examination by DEKRA, the results of which are laid down in report no. 3301649.07, dated January 24, 2011.

The examination has been carried out on one single specimen of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA

nhem, January 24, 2011

Number: 3301649.106

DEKRA Certification B.V.

H.L. Schendstok
Certification Manager

© Integral pub f this certificate and adjoining reports is allowed

All testing, inspec ting and certification activities of the former KEMA Quality are an integral part of the DEKRA Certification Group.

DEKRA Certification echtseweg 310, 6812 AR Arnhem P.O. Box 5185, 6802 ED Arnhem, The Netherlands
T +31 26 356 2000 F 52 5800 www.dekra-certification.com Company registration 09085396

LV5000A KEMA Test Certificate

TEST CERTIFICATE

Issued to:	Jiangsu Wetown Busway Co., Ltd. No. 1 Nanzi Road, Technology Park Xinba Town, Yangzhong, Jiangsu P. R. China
For the product:	Low-voltage busbar trunking system (copper bar) without tap off unit outlet
Trade name:	Wetown
Type/Model:	LV-5000 A
Ratings:	In: 5000 A, 50 Hz Ue: 690 V Icw: 3-phase 120 kA – 1,0 s with a peak of 264 kA Neutral 72 kA – 1,0 s with a peak of 158,4 kA PE 72 kA – 0,5 s with a peak of 158,4 kA
Manufactured by:	Jiangsu Wetown Busway Co., Ltd. No. 1 Nanzi Road, Technology Park Xinba Town, Yangzhong, Jiangsu P. R. China
Subject:	Type tests
Requirements:	IEC 60439-2, 3rd ed. 2000-03 and Amendment A1 2005-08 Clauses: 8.2.1, 8.2.2, 8.2.3, 8.2.4, 8.2.5, 8.2.7, 8.2.9, 8.2.10, 8.2.12 and 8.2.13
Remarks:	Not applicable

This Test Certificate is granted on account of an examination by DEKRA, the results of which are laid down in report no. 3301649.08, dated January 24, 2011.

The examination has been carried out on one single specimen of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA

Arnhem, January 24, 2011 Number: 3301649.107

DEKRA Certification B.V.

H.L. Schendstok
Certification Manager

© Integral publicat s certificate and adjoining reports is allowed

All testing, inspection, and certification activities of the former KEMA Quality are an integral part of the DEKRA Certification Group.

DEKRA Certification B.V. U weg 310, 6812 AR Arnhem P.O. Box 5185, 6802 ED Arnhem, The Netherlands
T +31 26 356 2000 F +31 26 0 www.dekra-certification.com Company registration 09085396

ROHS Certificate



China Quality Certification Center

中国质量认证中心

RoHS符合性认证证书

证书编号: CQC10130054324

Compliance of RoHS

产品名称

密集型母线槽及插接箱 Product Description

型号/规格

LV Busway & Tap off Box

申请人名称及地址

江苏威腾母线有限公司 Applicant
江苏省扬中市新坝科技园南自路1号 Jiangsu Wetown Busay

制造商名称及地址

江苏威腾母线有限公司 Manufacturer
江苏省扬中市新坝科技园南自路1号 Jiangsu Wetown Busay

生产厂名称及地址

江苏威腾母线有限公司
江苏省扬中市新坝科技园南自路1号

其他信息

无

测试报告编号

R723101101SH

根据所送样品的型式试验结果，符合
2002/95/EC, 2005/618/EC的要求，特此发证。

主 任：

发证日期: 2011年12月20日
有效期至: 2012年12月20日

中国质量认证中心

中国 · 北京 · 南四环西路 188 号 9 区 100070
http://www.cqc.com.cn

RF 0002062